



# Certificate of Compliance

**Certificate:** 1914639 (227924)

**Master Contract:** 227924

**Project:** 70046729

**Date Issued:** 2015-09-17

**Issued to:** Combustion Solutions Inc.  
39012 Discovery Way  
Squamish, British Columbia V8B 0E5  
CANADA  
Attention: Jamie Wardlaw

*The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US or with adjacent indicator 'US' for US only or without either indicator for Canada only.*



**Issued by:**

*Bret Ekstrand*  
Bret Ekstrand

## PRODUCTS

CLASS - C333501 - SYSTEMS (GAS)-Automatic Ignition and Components

CLASS - C333581 - SYSTEMS (GAS) - Automatic Ignition and Components - Certified to U.S. Standards

For details related to rating, size, configuration, etc. reference should be made to the CSA Certification Record or the descriptive report.

- For Use With Natural, Mfd., Mixed, Propane and Liq. Pet. Gases and LP Gas-Air Mixtures

Spark Ignition Control  
Trade Name: eHEnergizer  
PHE-24, PHE-120

## APPLICABLE REQUIREMENTS

ANSI Z21.20-2005  
Z21.20a-2008

Automatic Gas Ignition Systems And Components

CAN/CSA-C22.2 No. 199-M89 (R2004) Combustion Safety Controls and Solid-State Igniters for Gas- and  
Oil-Burning Equipment



## *Supplement to Certificate of Compliance*

**Certificate:** 1914639 (227924)

**Master Contract:** 227924

*The products listed, including the latest revision described below,  
are eligible to be marked in accordance with the referenced Certificate.*

### **Product Certification History**

---

<b>Project</b>	<b>Date</b>	<b>Description</b>
70046729	2015-09-17	Minimum ambient temperature increased from -50C to -45C. Continued Operation periodic test revised.
2724623	2014-07-24	Update drawings.
1914639	2008-07-30	Original Certification of model PHE-24 and PHE-120.